

VOC Content Test Certificate

Friday 15th December 2023

Supplier: Flame Security International (Level 5, Chemical Science Building F10, University of New South Wales, Kensington, NSW, 2033, AUSTRALIA).

Product Name: FSA FIRECOAT Interior Batch: 231020

Date Tested: 13th December 2023 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960-05 test method is referred in accordance with the laboratory testing guidance from Green Building Council of Australia.

Test Data:

Specification Green Building Council of Australia Green Star Design & As Built V1.3-13.1.1B Green Star Interiors V1.3-12.1.1B	FSA FIRECOAT Interior
Interior Wall and Ceiling Paint, all sheen levels: 16 grams per litre	10 grams per litre as VOC content per material
<i>We hereby certify FSA FIRECOAT Interior is below the VOC Content limits of chosen category specified by Green Star Design, Green Building Council of Australia</i>	

Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

Dr. Tuan Duong
PhD, BE (Chemical Engineer)
Senior Consultant

Travis Hale
BSc (Biotechnology)
Senior Consultant

Issue Date: 15/12/2023

Expiry date: 15 /12/2028

P23110051