

# VOC Content Test Certificate

Tuesday 04<sup>th</sup> May 2024

Supplier: Flame Security International (Level 5, Chemical Science Building F10, University of New South Wales, Kensington, NSW, 2033, AUSTRALIA).

Product Name: FSA FIRECOAT Exterior Batch: 231148

Date Tested: 21<sup>st</sup> May 2024 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ISO 11890-2:202: Paints and varnishes — Determination of volatile organic compound (VOC) content — Part 2: Gas-chromatographic method. ISO 11890-2 test method is referred in accordance with the laboratory testing guidance from Green Building Council of Australia.

Test Data:

<b>Specification</b> <b>Green Building Council of Australia</b> <b>Green Star Design &amp; As Built V1.3-13.1.1B</b> <b>Green Star Interiors V1.3-12.1.1B</b>	<b>FSA FIRECOAT Exterior</b> <b>Batch: 231148</b>
<b>Primers, Sealers, and Pre Coats Limits: 65 grams per litre</b>	<b>7.77 grams per litre as VOC content per material</b>
<i>We hereby certify FSA FIRECOAT Exterior Batch: 231148 is below the VOC Content limits of chosen category specified by Green Star Design, Green Building Council of Australia</i>	

Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant

Dr. Tuan Duong  
PhD, BE (Chemical Engineer)  
Senior Consultant

Travis Hale  
BSc (Biotechnology)  
Senior Consultant